

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 85

Dated. 05/06/2025

It is certified that an inspection team headed by Mr. Bharat Singh, ADO (Panchayat Sikandrabad)

(Name of Officers with designation) from Block Sikandrabad

(Name of Department/Office) inspected the **DIVINE ERA SCHOOL,**

DIVINE ERA SCHOOL, Dankaur Railway Road, Nizampur, Sikandrabad on 05/06/2025 and found that the DIVINE ERA SCHOOL has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

The above is valid for a period of April 05 To March 2026 till.

Signature with Seal

Name

Designation

Name & Address of the Office/Department: Block SKD

सहायक विकास अधिकारी (पंच)
विकास खण्ड सिकन्द्राबाद

Assistant Development Officer,
Block - SKD

To,

Divine Era School
Dankaur Railway Road Nizampur
Sikandrabad Distt - BSR
(Name & Address of the Institution)

The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



District Level Water Analysis Laboratory
UP Jal Nigam (Rural), Bulandshahr

TEST REPORT

UTR NO:	:	T 9249	
Sample receipt Date:	:	05/06/2025	
Customer/Party Name	:	LALIT SHARMA	
Address	:	Divine Era School Infront of Kalinga ITI Railway Road Nizampur Sikandrabad 203205	
Contact No.	:	9027430540	
Date of Sampling	:	05/06/2025	Sample Code: 27
Sample Description	:	06/06/2025	
Quantity	:	1	Water Source: Normal Water
Packing details	:		Sampling Method As per IS 17614:Part-2021
Analysis Start	:	05/06/2025	Analysis Completion Date 06/06/2025
Temperature	:	25.8°C	Humidity 63 %
Water Sample Provided By LALIT SHARMA			
Availability of Equipments:		Availability of reference standards:	Adequacy of sample quantity 01
Availability of Test method:	IS 3025	Availability of Trained person:	Duration of testing/Time of Report release 02:20p m

TEST PARAMETER

S. N.	Test Parameters	Method	Specification		Result	(Unit)
1	pH	IS 3025 (Part 11):2017	6.5-8.5	No Relaxation	7.375	-
2	Turbidity	IS 3025 (Part 10):2017	1.0	5.00	3.306	(NTU)*
3	TDS	IS 3025 (Part 16):2017	500	2000	680	(Mg/L)*
4	Chloride	IS 3025(Part 32): 2019	250	1000	155	(Mg/L)*
5	Total Alkalinity	IS 3025 (Part 23):1986	200	600	390	(Mg/L)*
6	Total Hardness	IS 3025 (Part 21):2019	200	600	560	(Mg/L)*
7	Colour	APHA 23 rd Edistion	5	15	12	Hazen
8	Taste	IS 3025 (Part 8) : 2017	Agreeable	Qualitative	Agreeable	Qualitative
9	Odour	IS 3025 (Part): 2018	Agreeable	Agreeable	Agreeable	Agreeable
10	E-Coli		0.0	No Relaxation	0.0	-
Remark		"The Information regarding sample collected, submitted and Customer basic details provided by the customer itself."				

Reviewed By

Lab Assistant

A

